

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170409

Address: 3570 SW HOLLYWOOD DR, Unit:7, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Michael Harkins	Partial	Tuesday, March 17, 2020

Corrective Action Required:

1	Misc	300,301, 304 tighten self closing hinges to make door latch
		302 anti tip device stove
		310 GFCI between stove & fridge not working
		309 GFCI end of island & USP not working
		210 GFCI master bath hot/neu rev
		204 tighten self closing hinges so door will latch

Comments: