

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182609
Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Wednesday, March 18, 2020

Partial Correction:

1	ELEVATOR 1	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT: 4TH- 3RD- 2ND- 1ST-
---	------------	--

SPACES BETWEEN JOISTS AT BACKSIDE:
BASEMENT:
1ST FLOOR: 1ST LAYER; 2ND LAYER;
2ND FLOOR: 1ST LAYER; 2ND LAYER
3RD FLOOR: 1ST LAYER; 2ND LAYER
4TH FLOOR:

Corrective Action Required:

2	STAIR TOWER 1	SPACES BETWEEN JOISTS AT BACKSIDE: 3RD FLOOR 1ST BASEMENT: EXTERIOR: 4TH FL- INTERIOR
---	---------------	--

		4TH FL:
		1ST LAYER;
Corrective Action Required:		
3	STAIR TOWER 2	SPACES BETWEEN JOISTS AT BACKSIDE: 3RD- FLOOR 1ST
		EXTERIOR:
		4TH FL-
		INTERIOR
		4TH FL:
		1ST LAYER;
Corrective Action Required:		
4	FOURTH FLOOR	Pre rock tub & showers 4th floor approved 1ST 2ND AT STAIR TOWNERS
Corrective Action Required:		
5	THIRD FLOOR	Pre rock tub & showers 3rd floor approved
Corrective Action Required:		
6	SECOND FLOOR	TUB SHOWERS - 1ST;
Corrective Action Required:		
7	FIRST FLOOR	TUB SHOWERS - 1ST;
Corrective Action Required:		
8	LOWER LEVEL	

Comments: