

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182607
Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Wednesday, March 18, 2020

Corrective Action Required:	
1 STAIR TOWER 1	INTERIOR WALLS , 2 LAYERS.
Corrective Action Required:	
2 STAIR TOWER 2	INTERIOR WALLS. 2 LAYERS
Corrective Action Required:	
3 ELEVATOR 1	1ST,2ND LAYER ELEVATOR SHAFT INSIDE 1st layer outside, exterior 1st layer
	CEILING 1,2,3,HAT CHANNEL.4th layer.
Corrective Action Required:	
4 FOURTH FLOOR	UNITS AND CORRIDORS
Corrective Action Required:	
5 THIRD FLOOR	RC-
	1ST,2ND LAYERS AT STAIRS AND ELEVATOR WALLS.
Corrective Action Required:	
6 SECOND FLOOR	RC-OK
Corrective Action Required:	
7 FIRST FLOOR	

Comments: