CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRSITE20183167Address:837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
DE - Sidewalk Inspection		Joe Starlin	Partial	Friday, October 04, 2019
Informational:				
1	Misc	5-15-19 The Sapp crew set forms to spec. Aggregate was compacted. They were informed to keep in compliance with ADA requirements and city spec.		
Informational:				
2	Misc	6-11-19 All sidewalk is ADA compliant except for one panel on the east side that comes into the approach. This panel was checked twice with myself and Bob Burns and will need replaced.		
Informational:				
3	Misc	8-28-19 They are setting up for sidewalk on the south side of the site. They needed some direction on ADA.		
Informational:				
4	Misc		setting up sidewalk around re planning on pouring tom	•
Informat	ional:			
5	Misc	• •	d the sidewalk by the dump opliance after it has set up.	ster, it still needs cured.

Comments: