

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183167
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	Joe Starlin	Partial	Wednesday, September 04, 2019

Informational:
1 Misc 8-28-19 We pulled the first water sample at 12:40pm Last sample was pulled 1:07pm. Samples were delivered to the lab at 1:40pm.

Comments: