

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20183167  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Sanitary Sewer - Vacuum</b>	Steve Robbins	Passed	Friday, August 09, 2019

Informational:  
1 Misc 4-17-19 The crew preformed a vacuum test at station 12+00. It has passed at this location.

Informational:  
2 Misc 8/9/19 vacuum test passed for 2C & 2B on line #2.

**Comments:**