

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191873
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Thursday, March 19, 2020

Corrective Action Required:

1	Miscellaneous Correction	FAILED EROSION CONTROL INSPECTION
---	--------------------------	-----------------------------------

There are numerous areas on site where the silt fence has failed and is allowing silt and mud to leave the site.

Make corrections to the erosion control devices asap to control the silt from leaving the site.

Comments: