CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

DE - Erosion Sediment Control John DiMauro Failed Thursday, March 19,

(ESC) Inspection 2020

Corrective Action Required:

1 Miscellaneous FAILED EROSION CONTROL INSPECTION

Correction

There are numerous areas on site where the silt fence has failed and is

allowing silt and mud to leave the site.

Make corrections to the erosion control devices asap to control the silt from

leaving the site.

Comments: