

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191897
Address: 3200 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	Ronald Paynter	Partial	Thursday, March 19, 2020

Corrective Action Required:

1	Misc	Silt in numerous areas through out the sub division. Roads need to be cleaned. RP 1-15-20
---	------	---

Corrective Action Required:

2	Misc	Silt has run off into the roadways in numerous areas. Gutter buddies is curb inlets also need to be cleaned out or replaced. RP 3-11-20
---	------	---

Informational:

3	Misc	Erosion control is still working at many locations. Need to rework 2 locations that are escaping into the storm system. Also need protection on the storm inlets located in the alleyways. RP 3-19-20
---	------	---

Comments: