

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193318  
Address: 4400 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Michael Harkins	Failed	Thursday, March 19, 2020

Corrective Action Required:

1	Misc	maintain silt fence Maintain gravel filter
---	------	---

Corrective Action Required:

2	Misc	FAILED EROSION CONROL
---	------	-----------------------

INSTALL PROPER SILT FENCE AND MAINTAIN IT.

INSTALL A CONSTRUCTION ENTRANCE IF SUFFICIENT SIZE AGGREGATE.

CLEAN MUD FROM THE STREET THAT WAS TRACKED FROM THIS SITE.

**Comments:**