

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200305  
Address: 659 SW 2ND ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	Michael Harkins	Failed	Friday, March 20, 2020

Corrective Action Required:

1	Misc	Conductors above drop ceiling shall be in MC check at above ceiling inspection
---	------	--

**Comments:**