

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182607
Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Friday, March 20, 2020

Corrective Action Required:

1	STAIR TOWER 1	INTERIOR WALLS , 2 LAYERS.
2	STAIR TOWER 2	INTERIOR WALLS. 2 LAYERS
3	ELEVATOR 1	1ST,2ND LAYER ELEVATOR SHAFT INSIDE 1st layer outside, exterior 1st layer

CEILING 1,2,3,HAT CHANNEL.4th layer.

Corrective Action Required:

4	FOURTH FLOOR	UNITS AND CORRIDORS
---	--------------	---------------------

Corrective Action Required:

5	THIRD FLOOR	RC-
---	-------------	-----

1ST,2ND LAYERS AT STAIRS AND ELEVATOR WALLS.
Wall type X & ceiling type C screw patterns units & corridors
Fire collars roof drains (4) bedroom closets

Corrective Action Required:

6	SECOND FLOOR	RC-OK
---	--------------	-------

Corrective Action Required:

7	FIRST FLOOR	RC-OK
---	-------------	-------

Corrective Action Required:

8 LOWER LEVEL RC garage ceilings OK

Comments: