

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192018
Address: 1521 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, March 20, 2020

Corrective Action Required:

1	Misc	- provide missing hangers (HUS26) at dining room girder - provide PFH portal framing garage per plan Sheet S2.0 detail 12 - provide 800 lb hold down device per plan EC #2 master , dining, single car garage - provide anchor bolts within 12" of plate breaks garage
---	------	---

Comments: