

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193328
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	Joe Starlin	Passed	Friday, March 20, 2020

Informational:
1 Misc 1-16-20 8:47am They are pulling the second round of samples from two locations. The pipes are frozen so we will try again at 1:30pm. Samples were pulled and have passed.

Comments: