

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20191576  
Address: 1808 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Monday, March 23, 2020

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- provide as graded plot plan -</li><li>- provide final grade, sod, splash blocks -</li><li>- provide covered deck pier inspections -</li><li>- provide switch &amp; receptacle cover plates</li></ul> Basement bedroom & bottom of stairs - <ul style="list-style-type: none"><li>- provide cover attic access laundry room -</li><li>- shear off set screw anti siphon device -</li><li>- GFCI mechanical room not working -</li><li>- provide cover plates at kitchen counter -</li><li>- provide (2) 3" screws each exterior hinge &amp; strike plate-</li><li>- seal exterior light fixtures -</li><li>- GFCI exterior HVAC equipment not working -</li></ul> |
|---|------|--|

**Comments:**