

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192138
Address: 1517 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Monday, March 23, 2020

Corrective Action Required:

1	Misc	<>Joist framing not deviates from plans. Revise plans to show header and joist change. Header bored for electrical multiple places , provide engineers report. 1st floor. > combustion air for basement, plans show 90%. Location of furnace changed. > loose insulation in dead space solid block or three-quarter inch plywood, bathroom off of the front hallway . Seal vent to roof at above > >Patio 6X6 poured in concrete. > correct all notched studs for plate bolts 4 locations in garage.
---	------	--

Comments: