

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192576
Address: 1534 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, March 23, 2020

Corrective Action Required:

1	Misc	- provide truss drawing & layout - address notched LVL above sliding glass door - Provide roof boot above pool bath floor - provide boca plate vent to roof at ceiling - provide boca plate vtr pool bath - provide missing H2.5 truss above mechanical room door
---	------	---

Comments: