

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170397

Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, March 23, 2020

Informational:

1 Misc

Bldg # 1

3rd floor all rough complete

2nd Floor

Screw downs hold downs throughout

Unit 210 fire caulk top plate near patio door, fire caulk corner bedroom moved sprinkler,

208 fire caulk low volt top plate kitchen, fire caulk bottom plate at service panel, bedroom top plate at patio, fire caulk sprinkler line bath

206 fire caulk bath top plate, FC corner both bedroom top plate 3x

207 fire caulk top plate kitchen,

209 FC water line fried top plate

204 provide hold down corner of bedroom,

205 FC top plate bath near DWV, hold down corner of bedroom, tighten nut hold down other bed

NE Stairway fire caulk top plate 2nd floor

SW fire caulk hole 2nd floor landing

Comments: