CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192732

Address: 2921 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Michael Harkins Failed Tuesday, March 24,

Residential 2020

Corrective Action Required:

1 Misc - provide as graded plot plan

- no footing inspection on record

- provide irrigation permit

- provide guardrail or raise grade to 30" front porch

- provide final grade, sod, down spouts

- AFCI breaker not working master & upper middle bedroom

- shear set screw on anti siphon device at main

- provide GFCI protection dish washer

- provide (2) 3" screws each exterior hinge & strike plate garage door

- install faucet & p trap bath at garage door

- GFCI at rear garage door not working

- seal exterior penetrations, top of meter can, A/C disconnect

Comments: