# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20191817

Address: 1200 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Tuesday, March 24,

Residential 2020

## Corrective Action Required:

1 Misc \*\* SHALL INSTALL EROSION CONTROL ALONG STREET AND AROUND REAR

CORNER. CLEAN UP STREET

- -Sidewalk not approved on record
- -Outside not inspected at this time. Make sure to seal all exterior lights and wall penetrations; sewer tracer wire port; 40 amp AC breaker match label
- -Install address
- -Final grade, sod
- -Garage door not self closing
- -Provide plan on site. Need to check something
- -Remove cover from smoke alarm
- -Install flood light bulbs
- -Deck: block/reinforce guardrail posts; handrail must extend to top riser
- -Install water heater and Install breaker lock. Do not block access to water

service shut-off valve and other valve

### **Comments:**