

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20200031

Address: 6 NW ORCHARD ST, LEES SUMMIT, MO 64063 10 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Vacuum	Steve Robbins	Passed	Wednesday, March 25, 2020

Informational:

1 Misc

I observed the vacuum test for both north and south manholes.

The north MH was approx 12' deep and it held at 10 on the gauge with no drop for 2.5 minutes. Test Passed.

The south MH was less than 10' deep and it held at 10 on the gauge with no drop for 2 minutes. Test Passed.

Comments: