

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20200031

Address: 6 NW ORCHARD ST, LEES SUMMIT, MO 64063 510 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Sanitary Sewer - Air Test</b>	John DiMauro	Passed	Wednesday, March 25, 2020

Informational:

1 Misc

I observed the air pressure test for the 8" line segment between the two manholes. The line is approximately 300' ft and it held at 4psi for 8 minutes with no drop. Test passed.

Informational:

2 Misc

I observed the air pressure test for the 8" line segment between the two manholes. The line is approximately 300' ft and it held at 4psi for 8 minutes with no drop. Test passed.

Informational:

3 Misc

I observed the air pressure test for the 8" line segment between the two manholes. The line is approximately 300' ft and it held at 4psi for 8 minutes with no drop. Test passed.

**Comments:**