

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192901  
Address: 1828 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, March 25, 2020

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>- land all conductors in a box</li><li>- provide 800 lb hold down device EC #2 per plan @ kitchen &amp; breakfast</li><li>- seal all upward penetrations throughout</li><li>- provide PFH portal frame garage door per plan</li><li>- anchor bolts shall be in middle 1/3 of the width of plate</li><li>- provide blocking at sheathing breaks above front door</li><li>- provide fire block entry closet near garage</li><li>- install bath exhaust</li><li>- provide truss hangers per schedule</li></ul> |
|---|------|---|

Comments: