

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20200031

Address: 6 NW ORCHARD ST, LEES SUMMIT, MO 64063 510 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector:   | Outcome: | Date:                     |
|--------------------------------------|--------------|----------|---------------------------|
| <b>DE - Sanitary Sewer - Mandrel</b> | John DiMauro | Passed   | Wednesday, March 25, 2020 |

Informational:

1 Misc

I observed the mandrel pull through the 8" sanitary sewer line with no deflection. I verified the correct mandrel size. Test passed.

**Comments:**