

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172529  
Address: 261 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Partial	Wednesday, March 25, 2020

Corrective Action Required:

3	THIRD FLOOR	3rd floor- Dryer boxes 5 sided throughout building, all fire blocking at dbl wall construction and floor ceiling penetrations, basement level at foundation wall vertical to horizontal, Draft stops at no more than 2 units or 3000 sq ft. < Submit Special inspection report for structural items. >
---	-------------	--

**Comments:**