

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192792
Address: 2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Inlets Clean	John Jackson	Failed	Wednesday, November 20, 2019

Corrective Action Required:

1	Misc	Contractor poured concrete used for collars and inverts to repair existing storm inlet wall that had to be partly extracted. The contractor (ESS) was informed that this did to meet the requirement for structural soundness. It would require proper reinforcement , concrete and forms. Contractor will continue to update me on repairs.
---	------	---

Comments: