

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20192368
Address: 713 SW 15TH CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Surface Course	John DiMauro	Passed	Wednesday, March 25, 2020

Informational:

1 Misc

Advanced Asphalt Paving Company installed the surface lift for the street. I verified the correct equipment, mix type and temperature of the install. Terrecon testing lab is on site. The preliminary density testing results were in compliance with 96 percent or better.

Comments: