

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190414  
Address: 2404 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Thursday, March 26, 2020

Corrective Action Required:

1

- No underslab inspection on record -
- no deck pier inspection on record (footing) ? -
- provide secondary lock sling glass door basement -
- provide access to juccuzzi tub motor (GFCI) -
- provide sump pump discharge pipe 3'-0" -

**Comments:**