## **CITY OF LEE'S SUMMIT Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20190209 Address: 2412 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Thursday, March 26, 2020
Corrective Action Required:			

Corrective Action Required:

1

- No deck pier inspection (footing?) -
- provide lockout device service panel for hood, range, microwave -
- provide (2) 3" screws each exterior hinge & strike plate -
- seal top of meter can -
- provide discharge pipe for sump -

**Comments:**