

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192670  
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Mark Harding	Partial	Thursday, March 26, 2020

Partial Correction:

1 Misc

LIGHT POLE PIERS/PADS APPROVED TO POUR:  
-2 NORTH AND SOUTH LP PEDESTALS AND PADS ON THE EAST SIDE PARKING LOT; ONE LP ON THE NORTH SIDE OF BUILDING

Corrective Action Required:

2 Misc

EAST LP PIER AT EAST PARKING LOT IS NOT MIN. 11 FT PER DESIGN. HAVE ENGINEER ADDRESS  
EMAIL ENG REPORT ON FIX.  
EAT CENTER AND NORTH POLE.

NOTE-ONLY3 REMAINING ON WEST SIDE

**Comments:**