

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20192218  
Address: 1901 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Proof roll parking lot</b>	Joe Starlin	Passed	Thursday, March 26, 2020

Informational:

1	Misc	3-26-20 1:53pm We are doing a proof roll on the parking lot at the park. They removed some asphalt base due to grade issues. The proof roll passed with corrections being made up to 7' of the curb. They will be adding 4" more inches of asphalt base to correct the problem. 3:39pm They are working on removing 4" of soft base.
---	------	--

**Comments:**