

PLANS REVIEW CONDITIONS

Permit No: PRCOM20193191	Date: March 27, 2020
Project Title: FIRST WATCH THE DAYTIME CAFE	Applicant:
Location: 920 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081	PALMER ELECTRIC CO 6600 ROYAL ST, BLDG B PLEASANT VALLEY, MO 64068
Type of Work:	
Occupancy Group: A-2	
Description: TENANT FINISH FOR BREAKFAST THEMED RESTAURANT	Primary: (816) 479-2587
Construction Type: Type VB (Unprotected)	
Map Page: 194D	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.