

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190679
Address: 222 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Mark Harding	Failed	Monday, March 30, 2020

Corrective Action Required:

1	Misc	RAMP-RETAINING WALL FOOTING- NO DETAIL ON PLANS CIVIL OR BUILDING. 8X18" WITH 2-#4 CONT. PROVIDE PLANS OR ENG APPROVAL.
---	------	--

Comments: