

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192901
Address: 1828 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Monday, March 30, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- provide 800 lb hold down device EC #2 per plan @ kitchen & breakfast (tighten anchor bolts on above)- seal upward penetration (master bed near tub , kitchen both sides of window above sink, above range, above 20 min door at garage)- provide PFH portal frame garage door per plan (5/8 anchor bolts, double bottom plate, 1 red lined plans in fireplace)- provide metallic tape bath exhaust fan (no electrical or duct tape)- provide truss hangers per schedule (powder bath @ garage LTHJA26)
---	------	--

Comments: