

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192007
Address: 1900 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Monday, March 30, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Seal around exterior light fixtures (NOT DONE)- Place splash blocks at gutter down spouts and sump pump discharge. Minimum distance 3' from foundation- Submit as graded plot plan for review prior to sod placement (NO AS GRADED PLOT PLAN IN DOCUMENTS)- Complete final grade and place sod <ul style="list-style-type: none">- No footing inspection on file as being completed. Please provide engineer report (NO FOOTING IN DOCUMENTS). Ok for TCO < (NO DECK PIER INSPECTION BY LS)>
---	------	--

Comments: