

Inspection Summary

Permit #: PRRES20191819, Building Permit - Residential

Address: 1208 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Steve Robbins	Passed	Monday, March 30, 2020

Informational

1 Driveway - forms and materials passed pre-inspection.

DE - Sidewalk Inspection	Steve Robbins	Passed	Monday, March 30, 2020
--------------------------	---------------	--------	------------------------------

Informational

1 Sidewalk- forms & materials passed pre-inspection.

Informational

2 The sidewalk has passed.

Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Monday, March 30, 2020
---	--------------	------------------	------------------------------

Corrective Action Required

1

- Sidewalk and driveway not approved on record
- Final grade, sod
- Deck: install hanger at deck beam connection to ledger; shim gap between joists and hangers
- Install anti-backflow device at hose bibb

Driveway Inspection

Steve Robbins

Passed

Monday,
March 30,
2020

Informational

1 Driveway - forms and materials passed pre-inspection.

Informational

2 Driveway passed.

Comments:
