

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200305
Address: 659 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Monday, March 30, 2020

Corrective Action Required:

1	Misc	- install vertical grab bar, TP, Mirror in rest room. - gfci outlets required left of sink and under counter at ice machine. - back flows on all hard piped fixtures to water piping. - License tax needs to be paid before TCO or COFO>
---	------	---

Comments: