

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172533
Address: 265 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|----------|-------------------------|
| Footing Inspection - Commercial | Michael Harkins | Partial | Tuesday, March 31, 2020 |

Informational:
1 Misc Bldg # 16 grade beams (2) #5 continuous
3/31/20 perimeter footing for garages (4) #5 cont

Comments: