

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191681
Address: 560 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Partial	Tuesday, March 31, 2020

Partial Correction:

1 Misc

WALLS APPROVED TO COVER:

-WALL ABOVE COOLER WINDOW, RM 107;

INSTALL PLUMBING SUPPORTS MID STORY ON DWV AT BATHS AND OFFICE, BREAK ROOM RECALL.

E COMMERCE ROOM NEEDS CORNER COMPLETE W/ELECT.

EXTERIOR STRUCTURAL FRAMING OK TO INSULATE:
SOUTH , EAST 1/2 WALL.

Comments: