

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20191610
Address: 1507 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, April 01, 2020
Inspected By: Tracy Deister
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Tracy Deister	Temporary C of O	Wednesday, April 01, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -Adjust water meter well to match final grade.
_ provide deck pier inspection covered deck
_ provide final grade & sod
_ provide (2) 3" screws each exterior hinge & strike plate

_provide city stamped plans check deck beam post attachment |
|---|------|---|