## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20191226

Address: 4705 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Thursday, April 02,

Residential 2020

Corrective Action Required:

1 Misc \*\*5/23-NOT READY FEE ASSESSED FOR NO EROSION CONTROL AT FOOTING

**INSPECTION** 

-As-graded plot plan is required prior to sodding

-Final grade, sod, downspout extensions
-Install tamper proof caps at the AC valves

-Missing middle deck pier; lag screws must go through the spacers; install

support device of outer joist to ledger board -Cover or remove insulation paper facing

-Furnace condensate drain must be able to be cleaned out

**Comments:**