

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192668
Address: 1825 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, April 02, 2020

Corrective Action Required:

1	Misc	- NO DECK PIER INSPECTION ON RECORED - - NAIL HANGERS POWDER ROOM - - NO PLUMBING IN POWDER ROOM ? - - PROVIDE LIB BRACING PER PLAN - - PROVIDE PFH PORTAL FRAMING PER PLAN - - TIGHTEN ANCHOR BOLTS BASEMENT - - PROVIDE DOUBLE FLOOR JOIST BASEMENT BETWEEN BEAMS FURNACE TO STEEL COLUMN PER PLAN -
---	------	---

Comments: