

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192780  
Address: 460 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:   | Inspector:   | Outcome: | Date:                       |
|---|--------------|----------|-----------------------------|
| <b>Underslab Electrical Inspection</b><br><b>- Commercial</b> | Mark Harding | Failed   | Thursday, March 26,<br>2020 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | INTERIOR CONDUIT SHELL BUILDING:<br>NW CORNER CONDUIT CUT OR BROKE RECALL FOR INSPECTION |
|---|------|--|

**Comments:**