

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192660
Address: 1533 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, April 03, 2020

Corrective Action Required:

1	Misc	- FIRE BLOCK TOP FUR OUT GREAT ROOM - - NAIL OFF SHEATHING AT LANDING TO 2ND FLOOR
---	------	---

Comments: