

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193693
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|------------------------|
| Underslab Plumbing Inspection - Commercial | Mark Harding | Failed | Friday, April 03, 2020 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Bed pipe in gravel full length of pipe. provide air test, Opsi. -- Areas of pipe are not supported by gravel. test is still at Opsi recall when ready. 2nd failed inspection |
|---|------|--|

Comments: