## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20190941

Address: 4520 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Michael Harkins Failed Friday, April 03, 2020

Residential

Corrective Action Required:

1 Misc - \*\* All water is to be discharge 3' from foundation, sump pump discharge

\*\* splash blocks needed

\*\*

-grading at north and west side needs to be fixed, grading cannot be within 6"

of siding -

## **Comments:**