

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193585
Address: 2920 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Michael Harkins	Failed	Friday, April 03, 2020

Corrective Action Required:
1 Misc - INSTALL GAS LINES PROVIDE PRESSURE FOR GAS TEST -

Comments: