

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192668  
Address: 1825 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Monday, April 06, 2020

Corrective Action Required:

1	Misc	- NO DECK PIER INSPECTION ON RECORDED -
		- SEAL UPWARD PENETRATIONS @ PLUMBING IN POWDER ROOM -
		- PROVIDE PFH PORTAL FRAMING PER PLAN -

**Comments:**