

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20182264  
Address: 1833 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Monday, April 06, 2020

Corrective Action Required:

- |   |      |                                                                                  |
|---|------|----------------------------------------------------------------------------------|
| 1 | Misc | - Please pay all outstanding inspection fees due at Development Services counter |
|   |      | - Obtain lawn irrigation system permit and submit backflow certification         |
|   |      | -                                                                                |
|   |      | - Several areas around perimeter where grade is within 6" from siding            |
|   |      | -                                                                                |
|   |      | - Provide documentation that all rough inspection was approved                   |

Comments: