

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193433
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Hydrostatic Test	Joe Starlin	Passed	Monday, April 06, 2020

Informational:

- | | | |
|---|------|--|
| 1 | Misc | 4-3-20 They were trying to test the fire line but the gauge they were using is not certified. We will try again at a later date. |
| 2 | Misc | 4-6-20 8:50am Kat Excavation has hooked up a certified pressure gauge on the fire line. It is at 200 psi and we will check it again in two hours. |
| 3 | Misc | 4-6-20 8:50am Kat Excavation has hooked up a certified pressure gauge on the fire line. It is at 200 psi and we will check it again in two hours. |
| 4 | Misc | 4-6-20 8:50am Kat Excavation has hooked up a certified pressure gauge on the fire line. It is at 200 psi and we will check it again in two hours. It has held just over 200 psi for two hours. |

Comments: